

CITY OF PALACIOS  
BID #2022-22  
PUMPS FOR BETHANY PARK LIFT STATION

KSB Model#9972147593/100 Pump Drive Shaft for Lift Station or City approved equal

**PART I – OVERVIEW**

**1.0 General Information**

1.1 City of Palacios Public Works is soliciting bids to purchase two pumps (100 gpm at 30 feet of head) with installation for the Bethany Park Lift Station or City approved equal in accordance with the specifications below. Contact Tammy McDonald for this solicitation at 361-972-3605 or [tmcdonald@cityofpalacios.org](mailto:tmcdonald@cityofpalacios.org) with all questions.

1.2 The specifications herein state the minimum requirements of the City of Palacios. All bids must be regular in every respect. Unauthorized conditions, limitations, or provisions shall be cause for rejection. The CITY may consider as "irregular" or "non-responsive", any bid not prepared and submitted in accordance with the bid documents and specification, or any bid lacking sufficient technical literature to enable the City of Palacios to make a reasonable determination of compliance to the specification. It shall be the bidder's responsibility to carefully examine each item of the specification, failure to offer a completed bid or failure to respond to each section of the technical specification (exception yes or no) will cause the proposal to be rejected without review as "non-responsive". All variances, exceptions, and/or deviations shall be fully described in the appropriate section; deceit in responding to the specification will be cause for rejection. Award may be based on best value to the City of Palacios ie.....delivery time or low price.

1.3 INTERPRETATIONS: In order to be fair to all bidders, no oral interpretations will be given to any bidder as to the meaning of the specification documents or any part thereof. Every request for each a consideration shall be made in writing to the City of Palacios. Based upon such inquiry, the City of Palacios may choose to issue an Addendum in accordance with Local Public Contract Laws.

**2.0 Solicitation Schedule**

EVENT DATE 10/28/2022

Email Solicitation Opens: 10/28/2022 08:00 AM CST

Site Visit can be Scheduled

Questions from Bidders to City of Palacios due by: 11/04/2022 05:00 PM CST

City of Palacios Answers to Questions due by: 11/05/2022 05:00 PM CST

Email Submittals due by: 11/10/2022 03:00 PM CST

Approved by Council (Estimated) 11/17/2022 6:00 PM CST

**PART II – SCOPE OF WORK**

**1.0 Technical Specifications or Scope of Work**

1.1 2 Pumps (100 gpm at 30 feet of head) with installation for Bethany Park Lift Station or City approved equal.

Note: You must include complete specifications sheet(s) with manufacturer name, model number and drawings

1.1.12 All interested bidders are encouraged to schedule site.

1.1.13 Bidders, on request of the City of Palacios, must be prepared to review their specifications with the City of Palacios and must, if requested. These services, if needed are considered as part of the bidder's proposal and will be provided without cost or obligation to the City of Palacios.

1.1.14 Units described shall be new, unused and of the current year's production. Unit shall be of the latest design and in current production completely serviced, ready for work and shall include all standard and optional equipment as specified herein.

1.1.15 The supplier shall be required to provide pumps and all fittings, parts, and modifications required.

1.1.16 If requested, all bidders must be able to demonstrate the unit they are bidding.

1.1.17 Must include installation of pumps.

## **1.2 Tools and Spare Parts**

1.2.1 Operations and Maintenance manuals.

## **1.3 Warranty**

1.3.1 Unit shall be warranted against defects in materials and workmanship for a period of 18 months from shipment or 12 months from start-up, whichever is less, and shall cover 100% parts and labor for the unit. Should the manufacturer's warranty exceed these requirements; the manufacturer's warranty shall be in effect. Warranty work shall be completed without cost to the City. It shall begin within 7 days after notification of the equipment failure or faulty material and shall be completed within a reasonable time frame, but not greater than 90 days. All freight charges to and from the vendor's repair facility shall be borne by the seller during the warranty period.

## **2.0 Delivery**

2.1 Delivery will be FOB Destination, Freight included in the unit cost.

2.2 Delivery Address: Bethany Park Lift Station • Palacios, Texas 77465

2.3 Delivery time: Monday – Friday from 8:00 am – 3:30 pm local time (except City approved holidays)

2.4 Forklifts and pallet jacks are available, if required.